# NOTICE OF SPECIFIED PENALTY

Date of Issue: December 12, 2018		Payment Due Date: January 11, 2019		
MSA File Number	2018-302	Specified Penalty Amount	\$750	
Registered Entity Name	EnerNOC Ltd.			
Asset ID (if applicable)	ENOL	Self-Report	⊠ YES □ NO	
ISO Rule	205.6	Date of Contravention	June 22, 2018	
Date of Referral/Self Report	July 23, 2018	This is the second contravention by this asset for this rule within a rolling 12 month period.		

On June 22, 2018 at approximately 15:39, the ENOL asset was directed to provide 8 MW of supplemental reserves load (SUPL). Ten minutes following the directive, the reduction in load from ENOL was less than the directed amount. Subsection 6(1) of section 205.6 of the ISO rules states:

A pool participant must, within ten (10) minutes following receipt of a directive to provide supplemental reserve, ensure that its pool asset is providing a quantity of real power equal to the instantaneous amount of real power of the pool asset at the time of the directive and the amount of real power set out in the directive.

### FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of ISO rule 205.6.

### MATERIAL FACTS

The material facts relied upon by the MSA include the following:

1. AESO generation, dispatch and directive data for ENOL for June 22, 2018.

2. Self-report submitted by EnerNOC Ltd. to the MSA dated July 23, 2018.

### DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made out to the "General Revenue Fund c/o Minister of Finance", and delivered to the Alberta Utilities Commission (AUC) at: 1400, 600 – 3rd Avenue S.W., Calgary, Alberta, T2P 0G5. Questions in respect of delivery of payment should be directed to the AUC. The payment should reference this notice and related MSA File #. Delivery of payment should also be confirmed by email to compliance@albertamsa.ca, with copy to the following AUC personnel: Jeremy Smith (Financial Accountant) Jeremy.Smith@auc.ab.ca, and Greg Andrews (Investigator) Greg.Andrews@auc.ab.ca.

## NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE				
Signature	"Original Signed"	Signature Date	December 12, 2018	
Name	Doug Doll	Title	Director, Corporate Services and Compliance	