

NOTICE OF SPECIFIED PENALTY

Date of Issue: September 20, 2019		Payment Due Date: October 21, 2019	
MSA File Number	2019-240	Specified Penalty Amount	\$750
Registered Entity Name	Irrigation Canal Power Co-op Ltd.		
Asset ID (if applicable)	RYMD	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
ISO Rule	203.3	Date of Contravention	June 3, 2019
Date of Referral/Self Report	June 6, 2019	This is the first contravention by this asset for this rule within a rolling 12 month period.	

EVENT DETAILS

On June 3, 2019, at approximately 23:48, RYMD received an advanced dispatch, effective at 00:00 June 4, for 9 MW of energy. At the time, RYMD was generating approximately 17 MW. RYMD submitted a MW block restatement at approximately 23:54 for settlement intervals within T-2, including HE 01 and HE 02 for June 4, 2019, from 9 MW to 14 MW. At approximately 23:57 RYMD accepted an advanced dispatch, effective at 00:00 June 4, for 14 MW of energy. Section 203.3 of the ISO Rules states in part:

- 4(1) A pool participant that submits an offer may submit a MW restatement prior to two (2) hours before the start of a settlement interval.
- (2) A pool participant that submits an offer must submit a MW restatement redistributing the MW to represent the operating state of the source asset, as soon as reasonably practicable, if the source asset cannot comply with the current offer as a result of:
- (a) either
 - (i) an acceptable operational reason; or
 - (ii) an operational deviation and such restatement is required under subsection 5(3) of section 203.4 of the ISO rules, *Delivery Requirements for Energy*; and
 an available capability restatement under subsection 2 cannot reasonably accommodate the source asset's operating state; or
 - (b) carrying out either one (1) or both of commissioning and testing under section 505.3 of the ISO rules, *Coordinating Synchronization, Commissioning, WECC Testing and Ancillary Services Testing* or under section 505.4 of the ISO rules, *Coordinating Operational Testing*.
- (3) A pool participant must submit the reason or reasons for submitting a MW restatement in accordance with subsection 4(2)(a) if such MW restatement is submitted within two (2) hours of the start of the settlement interval or within the current settlement interval.

FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of ISO rule 203.3.

MATERIAL FACTS

The material facts relied upon by the MSA include the following:

1. AESO available capability, dispatch, generation and energy offer data for RYMD for June 3, 2019.
2. Self-report Irrigation Canal Power Co-op Ltd. submitted to the MSA dated June 6, 2019.

DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made out to the "General Revenue Fund c/o Minister of Finance", and delivered to the Alberta Utilities Commission (AUC) at: 1400, 600 – 3rd Avenue S.W., Calgary, Alberta, T2P 0G5. Questions in respect of delivery of payment should be directed to the AUC. The payment should reference this notice and related MSA File #. Delivery of payment should also be confirmed by email to compliance@albertamsa.ca, with copy to the following AUC personnel: Jeremy Smith (Financial Accountant) Jeremy.Smith@auc.ab.ca, and Greg Andrews (Investigator) Greg.Andrews@auc.ab.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE

Signature	"Original Signed"	Signature Date	September 18, 2019
Name	Anders Renborg	Title	Director, Compliance