NOTICE OF SPECIFIED PENALTY				
Date of Issue: September 20, 2019		Payment Due Date: October 21, 2019		
MSA File Number	2019-377	Specified Penalty Amount	\$750	
Registered Entity Name	TransCanada Energy Ltd.			
Asset ID (if applicable)	BCRK	Self-Report	⊠ YES □ NO	
ISO Rule	205.8	Date of Contravention	July 30, 2019	
Date of Referral/Self Report	August 22, 2019	This is the second contravention by this asset for this rule within a rolling 12 month period.		

EVENT DETAILS

On July 30, 2019, during settlement intervals HE 12 through HE 18, BCRK was offline to perform a blade wash. BCRK did not submit any Transmission Must-Run (TMR) restatements to 0 MW, for the day of July 30, 2019. Section 205.8 of the ISO Rules states in part:

- 6(1) A pool participant may restate the declared availability of a generating source asset prior to receiving a dispatch for transmission must-run.
- (2) A pool participant must restate the declared capability of a source asset, in a timely manner, if there is a change in capability to supply the transmission must-run.

FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of ISO rule 205.8.

MATERIAL FACTS

The material facts relied upon by the MSA include the following:

- 1. AESO TMR restatement data for BCRK for July 30, 2019.
- 2. Self-report TransCanada Energy Ltd. submitted to the MSA dated August 22, 2019.

DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made out to the "General Revenue Fund c/o Minister of Finance", and delivered to the Alberta Utilities Commission (AUC) at: 1400, 600 – 3rd Avenue S.W., Calgary, Alberta, T2P 0G5. Questions in respect of delivery of payment should be directed to the AUC. The payment should reference this notice and related MSA File #. Delivery of payment should also be confirmed by email to compliance@albertamsa.ca, with copy to the following AUC personnel: Jeremy Smith (Financial Accountant) Jeremy.Smith@auc.ab.ca, and Greg Andrews (Investigator) Greg.Andrews@auc.ab.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE

Signature	"Original Signed"	Signature Date	September 17, 2019
Name	Anders Renborg	Title	Director, Compliance