

NOTICE OF SPECIFIED PENALTY

Date of Issue: July 19, 2021		Payment Due Date: August 19, 2021	
MSA File Number	2021-140	Specified Penalty Amount	\$250
Market Participant Name	Millar Western Forest Products Ltd.		
Asset ID (if applicable)	MW1U	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
ISO Rule Section	205.6	Date of Contravention	March 22, 2021
Date of Referral/Self Report	March 29, 2021	This is the first contravention by this asset for this section of the ISO rules within a rolling 12 month period.	

EVENT DETAILS

On March 22, 2021, at approximately 18:03:27, the MW1U asset received a directive to provide 31 MW of supplemental reserve. Ten minutes following the directive, the reduction in real power from MW1U was less than the directed amount, and over the course of the directive, the asset did not provide a response in accordance with the following subsections of section 205.6 of the ISO rules:

- 6(1) A pool participant must, within ten (10) minutes following receipt of a directive to provide supplemental reserve, ensure that its pool asset is providing a quantity of real power equal to the instantaneous amount of real power of the pool asset at the time of the directive and the amount of real power set out in the directive.
 - (2) A pool participant must ensure that, from the first time its pool asset achieves the response set out in subsection 6(1) to the time fifteen (15) minutes following receipt of the directive, the pool asset is providing an average response equal to or greater than the amount of real power set out in the directive.
 - (3) A pool participant must ensure that, for each consecutive ten (10) minute interval beginning fifteen (15) minutes following the receipt of a directive, the average response from the pool asset equals the amount of real power set out in the directive, within a tolerance of plus or minus:
 - (a) 5 MW for a pool asset with a maximum capability of 200 MW or less; or
 - (b) 10 MW for a pool asset with a maximum capability of greater than 200 MW.
 - (4) Where a pool asset does not have a maximum capability, the tolerances set out in subsection 6(3) will be measured against the maximum qualified facility capacity of the pool asset prescribed by the ISO.
 - (5) A pool participant must ensure that its pool asset continues to meet the requirements set out in subsection 6(3) for as long as the directive to provide supplemental reserve is in effect.
- [...]

FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of section 205.6 of the ISO rules.

MATERIAL FACTS

- The material facts relied upon by the MSA include the following:
1. AESO dispatch, directive, load and offer data for MW1U for March 22, 2021.
 2. Self-report submitted by Millar Western Forest Products Ltd. to the MSA dated March 29, 2021.

DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made payable to the "General Revenue Fund c/o Minister of Finance", and delivered to Alberta Energy at: 9945 – 108 Street NW, Edmonton, Alberta, T5K 2G6. The payment should reference this Notice of Specified Penalty and related MSA File #. Electronic copies of the payment and confirmation of delivery should be sent by email to compliance@albertamsa.ca and enforcement@auc.ab.ca. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE

Signature	"Original Signed"	Signature Date	July 19, 2021
Name	Andrew Wilkins	Title	Director, Compliance