

## NOTICE OF SPECIFIED PENALTY

Date of Issue: June 30, 2021		Payment Due Date: August 3, 2021	
MSA File Number	2021-166	<b>Specified Penalty Amount</b>	<b>\$5,000</b>
Market Participant Name	Voltus Energy Canada Ltd.		
Asset ID (if applicable)	VOED	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
ISO Rule Section	205.6	Date of Contravention	April 4, 2021
Date of Referral/Self Report	April 19, 2021	This is the fourth contravention by this asset for this section of the ISO rules within a rolling 12 month period.	

### EVENT DETAILS

On April 4, 2021, at approximately 21:38:46, the VOED asset received a directive to provide 53 MW of supplemental reserve supplied by load. Ten minutes following the directive, the reduction of load from VOED was less than the directed amount, and over the course of the directive, the asset did not provide a response in accordance with the following subsections. Section 205.6 of the ISO rules states, in part:

6(1) A pool participant must, within ten (10) minutes following receipt of a directive to provide supplemental reserve, ensure that its pool asset is providing a quantity of real power equal to the instantaneous amount of real power of the pool asset at the time of the directive and the amount of real power set out in the directive.

(2) A pool participant must ensure that, from the first time its pool asset achieves the response set out in subsection 6(1) to the time fifteen (15) minutes following receipt of the directive, the pool asset is providing an average response equal to or greater than the amount of real power set out in the directive.

(3) A pool participant must ensure that, for each consecutive ten (10) minute interval beginning fifteen (15) minutes following the receipt of a directive, the average response from the pool asset equals the amount of real power set out in the directive, within a tolerance of plus or minus:

(a) 5 MW for a pool asset with a maximum capability of 200 MW or less; or

(b) 10 MW for a pool asset with a maximum capability of greater than 200 MW.

(4) Where a pool asset does not have a maximum capability, the tolerances set out in subsection 6(3) will be measured against the maximum qualified facility capacity of the pool asset prescribed by the ISO.

### FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of section 205.6 of the ISO rules.

### MATERIAL FACTS

The material facts relied upon by the MSA include the following:

1. AESO dispatch, directive, load and offer data for VOED for April 4, 2021.
2. Self-report submitted by Voltus Energy Canada Ltd. to the MSA dated April 19, 2021.

### DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made payable to the "General Revenue Fund c/o Minister of Finance", and delivered to Alberta Energy at: 9945 – 108 Street NW, Edmonton, Alberta, T5K 2G6. The payment should reference this Notice of Specified Penalty and related MSA File #. Electronic copies of the payment and confirmation of delivery should be sent by email to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) and [enforcement@auc.ab.ca](mailto:enforcement@auc.ab.ca). Questions can be directed to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

## NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

## SIGNATURE

Signature	"Original Signed"	Signature Date	June 30, 2021
Name	Andrew Wilkins	Title	Director, Compliance