

NOTICE OF SPECIFIED PENALTY

Date of Issue: March 24, 2025		Payment Due Date: April 24, 2025	
MSA File Number	2024-383	Specified Penalty Amount	\$250
Market Participant Name	Enfinite Corporation		
Asset ID (if applicable)	ERV2	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
ISO Rule Section	205.9	Date of Contravention	September 28, 2024
Date of Referral/Self Report	October 25, 2024	This is the first contravention by this asset for this section of the ISO rules within a rolling 12-month period.	

MSA FINDINGS

On September 28, 2024, during the hour ending ('HE') 20 and 21, ERV2 was armed to provide 20 MW of Fast Frequency Response (FFR). During the minute-ending 19:54, the frequency of the Alberta Interconnected Electrical System (AIES) deviated below 59.6 Hz, triggering the ERV2 response. Information available to the MSA indicates that the asset did not provide a response as specified in its contract. Section 205.9 of the ISO rules states, in part:

- 5(1) The market participant must, when armed to provide fast frequency response service:
- (a) maintain an actual volume of fast frequency response service that is at or above the armed volume specified in the contract or otherwise directed by the ISO; and
 - (b) provide a response when the frequency of the interconnected electric system becomes less than or equal to the target frequency specified in the contract, or otherwise directed by the ISO: (i) by reducing real power flow into the facility, or increasing real power flow from the facility into the interconnected electric system; (ii) by an amount that is at or above the tolerance specified in the contract, and (iii) within the response time specified in the contract.

The MSA is satisfied that the event was a contravention of ISO rule 205.9.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Mark Nesbitt, Director, Enforcement on March 24, 2025