

NOTICE OF SPECIFIED PENALTY

Date of Issue: May 26, 2025		Payment Due Date: June 26, 2025	
MSA File Number	2025-058	Specified Penalty Amount	\$500
Market Participant Name	TransAlta Generation Partnership		
Asset ID (if applicable)	KH3	Self-Report	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
ISO Rule Section	203.4	Date of Contravention	May 29, 2024
Date of Referral/Self Report	February 6, 2025	This is the first contravention by this asset for this section of the ISO rules within a rolling 12-month period.	

MSA FINDINGS

On May 29, 2024, the KH3 asset received a dispatch to 0 MW with an effective time of 13:00. Shortly after 13:00, an operational deviation occurred which prevented the KH3 asset from ramping towards its dispatch level. At 13:59 the AESO System Controller was called to inform them that the KH3 asset was experiencing issues coming offline. Information available to the MSA indicates that KH3 did not reach its allowable dispatch variance until 22:47, and that an available capability or MW restatement was not made. Section 203.4 of the ISO rules states, in part:

- 5(1) A pool participant must, if a source asset experiences an operational deviation, verbally inform the ISO as soon as practicable of the occurrence of the operational deviation and provide a description of the cause if known.
- (2) A pool participant must inform the ISO of the information required under subsection 5(1) on a telephone line the ISO designates, which must contain a voice recording system.
- (3) A pool participant must, if an operational deviation extends for 20 minutes or longer, submit an available capability restatement or MW restatement for the source asset that represents the operational capability of the source asset and must do so no later than 20 minutes after the commencement of the operational deviation.

The MSA is satisfied that the event was a contravention of ISO rule 203.4.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Derek Olmstead, Administrator & Chief Executive Officer on May 26, 2025