

## NOTICE OF SPECIFIED PENALTY

Date of Issue: May 26, 2025		Payment Due Date: June 26, 2025	
MSA File Number	2025-110	<b>Specified Penalty Amount</b>	<b>\$250</b>
Market Participant Name	Canadian Hydro Developers, Inc.		
Asset ID (if applicable)	SUM1	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
ISO Rule Section	205.9	Date of Contravention	March 7, 2025
Date of Referral/Self Report	March 18, 2025	This is the first contravention by this asset for this section of the ISO rules within a rolling 12-month period.	

### MSA FINDINGS

SUM1 is a battery energy storage system with a maximum capability of 10 MW. At the beginning of the hour ending ('HE') 20 on March 7, 2025, the SUM1 asset was under dispatch for 10 MW of spinning reserve. At approximately 19:33, the SUM1 asset offered 10 MW into Fast Frequency Response ('FFR'). Information available to the MSA indicates that between 19:33 and 20:00, SUM1 was simultaneously dispatched to 10 MW of spinning reserve while also offering 10 MW of FFR. Section 205.9 of the ISO rules states, in part:

(7) The market participant must not use the capacity it makes available or that is dispatched to provide fast frequency response service to simultaneously provide operating reserves.

The MSA is satisfied that the conduct was a contravention of section 205.9 of the ISO rules.

### DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) for instructions. When submitting the EFT, please send an email to [AU.FinOps@gov.ab.ca](mailto:AU.FinOps@gov.ab.ca), [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) and [enforcement@auc.ab.ca](mailto:enforcement@auc.ab.ca) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

### NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

### APPROVED BY

Derek Olmstead, Administrator & Chief Executive Officer on May 26, 2025