

## NOTICE OF SPECIFIED PENALTY

Date of Issue: February 18, 2026		Payment Due Date: March 20, 2026	
MSA File Number	2025-348 & 2025-338	<b>Specified Penalty Amount</b>	<b>\$500</b>
Market Participant Name	General Land & Power Corp.		
Asset ID (if applicable)	SLR1	Self-Report	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
ISO Rule Section	502.16	Date of Contravention	June 22, 2024
Date of Referral/Self Report	August 15, 2025	This is the first contravention by this asset for this section of the ISO rules within a rolling 12-month period.	

### MSA FINDINGS

Information available to the MSA indicates that model validation and reactive power verification report for the SLR1 asset was not submitted to the AESO within 180 days following connection, as required under subsection 13(2) of Section 502.16 which states, in part:

**13(2)** In addition to any other reporting requirements specified in this Section 502.16 the **legal owner** of an **aggregated generating facility** must, unless otherwise specified in this Section 502.16, submit a separate model validation and reactive power verification report in accordance with subsection 13(1) to the **ISO** no later than one hundred and eighty (180) **days** after the date of completion of each of:

- (a) the first connection of an **aggregated generating facility** to the **transmission system** or a **transmission facility** within the service area of the City of Medicine Hat;

The MSA is satisfied that the conduct was a contravention of Section 502.16 of the ISO rules.

### DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) for instructions. When submitting the EFT, please send an email to [AU.FinOps@gov.ab.ca](mailto:AU.FinOps@gov.ab.ca), [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) and [enforcement@auc.ab.ca](mailto:enforcement@auc.ab.ca) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

### NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca).

### APPROVED BY

Mike Morganton, Executive Director, Enforcement, on February 12, 2026