

# NOTICE OF SPECIFIED PENALTY

Date of Issue: May 29, 2026		Payment Due Date: June 29, 2026	
MSA File Number	2025-482	<b>Specified Penalty Amount</b>	<b>\$250.00</b>
Market Participant Name:	Canadian Forest Products Ltd.		
Asset ID (if applicable)	GPEC	Self-Report	Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
ISO Rule Section	502.6	Date of Contravention:	October 01, 2024
Date of Referral/Self Report	December 02, 2025	This is the 1st contravention by this asset for this section of the ISO rules within a rolling 12-month period.	

## MSA FINDINGS

ISO rule 502.6 states:

11(1) The legal owner of a generating unit must, for each model referenced in subsection 11(2) perform model revalidation testing not later than five (5) years from the date of the most recently completed baseline testing or model revalidation testing.

12(1) The legal owner of a generating unit must, subject to subsection 12(3), perform reactive power verification testing of the generating unit at the maximum authorized real power for the generating unit at regular intervals no later than five (5) years from the date of the prior reactive power verification or re-verification testing.

Information available to the MSA indicates that model revalidation and reactive power verification testing for the GPEC asset was due to be completed by October 1, 2024 and as of December 2025 the required testing had yet to be completed.

The MSA is satisfied that the conduct was a contravention of Section 502.6 of the ISO rules.

## DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>) for instructions. When submitting the EFT, please send an email to [AU.FinOps@gov.ab.ca](mailto:AU.FinOps@gov.ab.ca) (<mailto:AU.FinOps@gov.ab.ca>), [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>) and [enforcement@auc.ab.ca](mailto:enforcement@auc.ab.ca) (<mailto:enforcement@auc.ab.ca>) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>).

## NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>).

**APPROVED BY**

Mike Morganton, Executive Director, Enforcement on May 28, 2026