

NOTICE OF SPECIFIED PENALTY

Date of Issue: April 24, 2018		Payment Due Date: May 24, 2018	
MSA File Number	RS2018-003	Specified Penalty Amount	\$5,000
Registered Entity Name	TransAlta Generation Partnership		
Reliability Standard	PRC-001-AB1-1 / PRC-001-AB2-1	Self-Report	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
Requirement	R1	Accepted Mitigation Plan	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
Date of Referral/Self Report	January 12, 2018	Date of Contravention	July 1, 2014 to December 8, 2015

EVENT DETAILS

Pursuant to the Alberta Electric System Operator (AESO) Alberta Reliability Standards 2017–2019 audit schedule, the AESO conducted a scheduled Q3/2017 compliance monitoring audit of TransAlta Generation Partnership. The applicable audit period with respect to PRC-001-AB1-1 / PRC-001-AB2-1 extended from July 1, 2014 to June 30, 2017. Based upon the AESO audit findings, PRC-001-AB1-1 / PRC-001-AB2-1 was contravened as follows:

Between July 1, 2014 to December 8, 2015, TransAlta Generation Partnership was unable to demonstrate that all operating personnel at Keephills 1 and 2 were familiar with the purpose and limitations of protection system schemes applied in its area. PRC-001-AB1-1 / PRC-001-AB2-1 states, in part:

R1 The operating personnel of each of the ISO, the operator of a transmission facility, the operator of a generating unit and the operator of an aggregated generating facility must be familiar with the purpose and limitations of protection system schemes applied in its area.

MR1 Training records are available that indicate training of staff who operate the system in protection system schemes and any remedial action scheme applicable within their system.

FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of Reliability Standard PRC-001-AB1-1 / PRC-001-AB2-1, requirement R1.

MATERIAL FACTS

The material facts relied upon by the MSA include the following:

- Referral from the AESO to the MSA dated January 12, 2018, including the AESO Alberta Reliability Standards Compliance Monitoring Audit Report on the AESO Q3/2017 compliance monitoring audit of TransAlta Generation Partnership.

DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made out to the “General Revenue Fund c/o Minister of Finance”, and delivered to the Alberta Utilities Commission (AUC) at: 1400, 600 – 3rd Avenue S.W., Calgary, Alberta, T2P 0G5. Questions in respect of delivery of payment should be directed to the AUC. The payment should reference this notice and related MSA File #. Delivery of payment should also be confirmed by email to compliance@albertamsa.ca, with copy to the following AUC personnel: Jeremy Smith (Financial Accountant) Jeremy.Smith@auc.ab.ca, and Greg Andrews (Investigator) Greg.Andrews@auc.ab.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened a reliability standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE

Signature	"Original Signed"	Signature Date	April 24, 2018
Name	Andrew Wilkins	Title	Manager, Compliance