

NOTICE OF SPECIFIED PENALTY

Date of Issue: February 25, 2025		Payment Due Date: March 25, 2025	
MSA File Number	RS2024-163	Specified Penalty Amount¹	\$ 1,500
Market Participant Name	ENMAX Power Corporation		
Reliability Standard	EOP-008-AB-1	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Requirement	R1	Accepted Mitigation Plan	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date of Self Report	July 24, 2024	Date of Contravention	June 23, 2024

MSA FINDINGS

Enmax Power Corporation contravened Requirement 1(e) of EOP-008-AB-1 from June 23, 2024, to October 8, 2024, as its operating plan describing the manner in which it continues to meet its functional obligations with regard to the reliable operations of the bulk electric system in the event that its primary control centre functionality is lost was not sufficient to enable a transition period between the decision to transfer functionality to the back up control centre following the loss of primary control centre functionality and the time to fully implement the backup functionality that is less than or equal to two (2) hours.

Requirement 1 of EOP-008-AB-1 states, in part:

The ISO and each operator of a transmission facility must have a current operating plan describing the manner in which it continues to meet its functional obligations with regard to the reliable operations of the bulk electric system in the event that its primary control centre functionality is lost.

This operating plan for backup functionality must include the following, at a minimum:

(e) a transition period between the decision to transfer functionality to the back up control centre following the loss of primary control centre functionality and the time to fully implement the backup functionality that is less than or equal to two (2) hours;

The MSA is satisfied that the conduct was a contravention of Reliability Standard EOP-008-AB-1, requirement R1.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Mark Nesbitt, Director, Enforcement on February 24, 2025

¹ Specified penalty amount conditional on the completion of the accepted Mitigation Plan.