

NOTICE OF SPECIFIED PENALTY

Date of Issue: February 25, 2025		Payment Due Date: March 25, 2025	
MSA File Number	RS2024-164	Specified Penalty Amount¹	\$ 2,500
Market Participant Name	ENMAX Power Corporation		
Reliability Standard	COM-001-AB-3	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Requirement	R15.A1	Accepted Mitigation Plan	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date of Self Report	July 24, 2024	Date of Contravention	June 23, 2024

MSA FINDINGS

Enmax Power Corporation contravened requirement R15.A1 of COM-001-AB-3 on June 23, 2024, as it failed to have sufficient backup power supply to ensure that its backup voice communication capability, in its control room site, was capable of remaining operational for a minimum of 8 hours in the event of an extended power outage of its main power supply for its backup voice communication capability.

Requirement R15.A1 of COM-001-AB-3 states:

Each Responsible Entity shall, where its backup voice communication capability is a satellite telephone service or utility orderwire service, have sufficient backup power supply to ensure that its backup voice communication capability, in its control room site, is capable of remaining operational for a minimum of 8 hours in the event of an extended power outage of its main power supply for its backup voice communication capability.

The MSA is satisfied that the conduct was a contravention of Reliability Standard COM-001-AB-3, requirement R15.A1.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Mark Nesbitt, Director, Enforcement on February 24, 2025

¹ Specified penalty amount conditional on the completion of the accepted Mitigation Plan.