

NOTICE OF SPECIFIED PENALTY

Date of Issue: February 12, 2026		Payment Due Date: March 16, 2026	
MSA File Number	RS2025-114	Specified Penalty Amount	\$ 7,500
Market Participant Name	ATCO Electric Ltd.		
Reliability Standard	PRC-001-AB3-1.1(ii)	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Requirement	R6	Accepted Mitigation Plan	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date of Referral/Self Report	July 21, 2025	Date of Contravention	January 14, 2025

MSA FINDINGS

Requirement R6 of PRC-001-AB3-1.1(ii) states, in part:

R6 Each operator of a transmission facility must monitor the status (on/off) of each remedial action scheme in its area, and must notify the ISO and each affected:

- (a) operator of a transmission facility;
- (b) adjacent interconnected transmission operator;
- (c) operator of a generating unit; and
- (d) operator of an aggregated generating facility, of each change in status.

The MSA is satisfied that a contravention ATCO Electric Ltd. contravened requirement R6 of PRC-001-AB3-1.1(ii) from January 14, 2025, to June 13, 2025.

The MSA determined this contravention to be at a High severity due to the duration of the contravention and the potential impact to reliability from the AESO not receiving correct information about the status of a remedial action scheme.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Daniela Cismaru - Advisor, Alberta Reliability Standards on February 11, 2026