

# NOTICE OF SPECIFIED PENALTY

Date of Issue: June 05, 2026		Payment Due Date: July 06, 2026	
MSA File Number	RS2025-148	<b>Specified Penalty Amount<sup>1</sup></b>	<b>\$2,500.00</b>
Market Participant Name:	MEG Energy Corp.		
Reliability Standard	PRC-005-AB2-6	Self-Report	Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
Requirement	R3	Accepted Mitigation Plan	Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
Date of Referral / Self Report	September 05, 2025	Date of Contravention:	June 30, 2025 - August 11, 2025

## MSA FINDINGS

Requirement R3 of PRC-005-AB2-6 states, in part:

R3 Each legal owner of a transmission facility, legal owner of a generating unit, and legal owner of an aggregated generating facility that uses time-based maintenance program(s) must maintain its protection system, automatic reclosing, and sudden pressure relaying components that are included within the time-based maintenance program in accordance with the minimum maintenance activities and maximum maintenance intervals prescribed within Tables 1-1 through 1-5, Table 2, Table 3, Tables 4-1 through 4-3, and Table 5 of Appendix 1.

From June 30, 2025, to August 11, 2025, MEG Energy Corp. did not complete the required maintenance activities as prescribed in Appendix 1 of PRC-005-AB2-within Table 1-4(a) for the G2 Station DC Battery Bank, resulting in a contravention of PRC-005-AB2-6 requirement R3. The MSA is satisfied that the conduct was a contravention of PRC-005-AB2-R3 for a period of 42 days.

The MSA determined that the contravention was of Lower severity.

## DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>) for instructions. When submitting the EFT, please send an email to [AU.FinOps@gov.ab.ca](mailto:AU.FinOps@gov.ab.ca) (<mailto:AU.FinOps@gov.ab.ca>), [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>) and [enforcement@auc.ab.ca](mailto:enforcement@auc.ab.ca) (<mailto:enforcement@auc.ab.ca>) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>).

## NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance unless it qualifies for the public reporting exception for critical infrastructure protection (CIP) contraventions in s. 5.3 of AUC Rule 027. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at [compliance@albertamsa.ca](mailto:compliance@albertamsa.ca) (<mailto:compliance@albertamsa.ca>).

**APPROVED BY**

Johanne Poirier Mouallem, Advisor, Alberta Reliability Standards on June 05, 2026

<sup>1</sup>Specified penalty amount conditional on the completion of the accepted Mitigation Plan.