

NOTICE OF SPECIFIED PENALTY

Date of Issue: June 10, 2026		Payment Due Date: July 10, 2026	
MSA File Number	RS2025-169	Specified Penalty Amount	\$3,750.00
Market Participant Name:	Cenovus Energy Inc.		
Reliability Standard	PRC-005-AB2-6	Self-Report	Yes: <input checked="" type="checkbox"/> No: <input type="checkbox"/>
Requirement	R3	Accepted Mitigation Plan	Yes: <input type="checkbox"/> No: <input checked="" type="checkbox"/>
Date of Referral / Self Report	September 11, 2025	Date of Contravention:	October 01, 2025 - November 25, 2025

MSA FINDINGS

Requirement R3 of PRC-005-AB2-6 states:

R3 Each legal owner of a transmission facility, legal owner of a generating unit, and legal owner of an aggregated generating facility that uses time-based maintenance program(s) must maintain its protection system, automatic reclosing, and sudden pressure relaying components that are included within the time-based maintenance program in accordance with the minimum maintenance activities and maximum maintenance intervals prescribed within Tables 1-1 through 1-5, Table 2, Table 3, Tables 4-1 through 4-3, and Table 5 of Appendix 1.

Based on the information provided by Cenovus Energy Inc., the MSA is satisfied that a contravention of Requirement R3 of PRC-005-AB-6 has occurred from October 1, 2025 to November 25, 2025, as the maintenance activities pertaining to CL1-09-PCB-9201 and CL1-09-PCB-9202 were not performed in accordance with the schedules prescribed in Table 1-5.

The MSA deemed this contravention to be of Lower severity.

Cenovus did not provide a mitigation plan.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>) for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca (<mailto:AU.FinOps@gov.ab.ca>), compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>) and enforcement@auc.ab.ca (<mailto:enforcement@auc.ab.ca>) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>).

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance unless it qualifies for the public reporting exception for critical infrastructure protection (CIP) contraventions in s. 5.3 of AUC Rule 027. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>).

APPROVED BY

Daniela Cismaru, Advisor, Alberta Reliability Standards on June 08, 2026