

NOTICE OF SPECIFIED PENALTY

Date of Issue: January 23, 2026		Payment Due Date: February 23, 2026	
MSA File Number	RS2025-180 & RS2025-181	Specified Penalty Amount	\$ 5,000
Market Participant Name	ENMAX Energy Corporation		
Reliability Standard	VAR-002-AB-4.1	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Requirement	R1, R3	Accepted Mitigation Plan	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date of Referral/Self Report	October 7, 2025	Date of Contravention	July 29, 2025

MSA FINDINGS

Requirement R1 and R3 of VAR-002-AB-4.1 states, in part:

R1 The operator of a generating unit and operator of an aggregated generating facility must, while a generating unit or aggregated generating facility is electrically connected to the transmission system, operate the generating unit or aggregated generating facility with its automatic voltage regulator or voltage regulating system in service and in automatic voltage control mode, or in a different control mode as instructed by the ISO unless:

[...]

R3 Each operator of a generating unit and operator of an aggregated generating facility must notify the ISO within 30 minutes after a status or control mode change of the automatic voltage regulator, voltage regulating system, alternative voltage controlling device or power system stabilizer, as applicable, on any generating unit or aggregated generating facility.

The MSA is satisfied that the conduct was a contravention of VAR-002-AB-4.1, requirements R1 and R3 as Taber Wind Farm was not operated with the voltage regulating system in automatic voltage control mode from July 29, 2025 to September 8, 2025.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Daniela Cismaru - Advisor, Alberta Reliability Standards on January 16, 2026