

NOTICE OF SPECIFIED PENALTY

Date of Issue: February 12, 2026		Payment Due Date: March 16, 2026	
MSA File Number	RS2025-215	Specified Penalty Amount	\$ 12,500
Market Participant Name	ATCO Electric Ltd.		
Reliability Standard	FAC-003-AB1-1	Self-Report	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Requirement	R1	Accepted Mitigation Plan	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date of Referral/Self Report	December 1, 2025	Date of Contravention	February 13, 2023

MSA FINDINGS

Requirement R1 of FAC-003-AB1-1 states, in part:

Each legal owner of a transmission facility must prepare a TVMP. This program is to be updated at least annually. The TVMP must include the objectives, practices, approved procedures, and work specifications 1 of the legal owner of a transmission facility.

[...]

The MSA is satisfied that ATCO Electric Ltd. contravened requirement R1 of FAC-003-AB1-1 as line 9LA59 was not included in the Transmission Vegetation Management Program from February 13, 2023 to November 20, 2025.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca, compliance@albertamsa.ca and enforcement@auc.ab.ca noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

APPROVED BY

Daniela Cismaru - Advisor, Alberta Reliability Standards on February 11, 2026