

NOTICE OF SPECIFIED PENALTY

Date of Issue: August 07, 2026		Payment Due Date: September 07, 2026	
MSA File Number	RS2026-031	Specified Penalty Amount¹	\$5,000.00
Market Participant Name:	Pembina NGL Corporation		
Reliability Standard	PRC-005-AB2-6	Self-Report	Yes: ☒ No: ☐
Requirement	R1	Accepted Mitigation Plan	Yes: ☒ No: ☐
Date of Referral / Self Report	February 03, 2026	Date of Contravention:	December 21, 2024 - August 07, 2026

MSA FINDINGS

Requirement R1 of PRC-005-AB2-6 states

R1 Each legal owner of a transmission facility, legal owner of a generating unit, and legal owner of an aggregated generating facility must establish a protection system maintenance program for its protection systems, automatic reclosing, and sudden pressure relaying.

Based on the information provided by Pembina NGL Corporation (Pembina), the Market Surveillance Administrator is satisfied that Pembina contravened Requirement R1 of PRC-005-AB2-6 during the period of December 21, 2024, to August 7, 2026, as a protection system maintenance program for its protection systems, automatic reclosing, and sudden pressure relaying was not established.

The MSA assessed this contravention as Severe due to its duration.

The MSA accepted the mitigation plan, in accordance with section 4.9(c) of AUC Rule 027, as the actions correct the contravention and are intended to prevent reoccurrence of the root cause.

DELIVERY OF PAYMENT

Payment can be made by electronic funds transfer (EFT). Please reach out to compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>) for instructions. When submitting the EFT, please send an email to AU.FinOps@gov.ab.ca (<mailto:AU.FinOps@gov.ab.ca>), compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>) and enforcement@auc.ab.ca (<mailto:enforcement@auc.ab.ca>) noting the MSA file #, market participant name, name as appears on bank account, payment amount and the date of the payment. Questions can be directed to compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>).

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an Alberta Reliability Standard. Specified penalties are set out in AUC Rule 027.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5.1 of AUC Rule 027 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance unless it qualifies for the public reporting exception for critical infrastructure protection (CIP) contraventions in s. 5.3 of AUC Rule 027. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca (<mailto:compliance@albertamsa.ca>).

APPROVED BY

Daniela Cismaru, Advisor, Alberta Reliability Standards on August 07, 2026

¹Specified penalty amount conditional on the completion of the accepted Mitigation Plan.